

GENERAL FIRE

3904-4004 E. Trent
www.generalfire.com

Spokane, WA. 99202
509-535-4244
800-541-4218



DESCRIPTION: LED Compartment Lighting

PLANT: Central

SPECIFICATION: One (1) ROM vertically mounted roll-up compartment LED door light shall be installed on one side of the door opening. The compartment light shall be integrated into the roll-up door track with the light actuation with the door opening. The light shall have a polycarbonate lens to eliminate breakage from impact and eliminate heat build up. (55-01-1150)

Two (2) ROM vertically mounted roll-up compartment LED door lights shall be installed one each side of the door opening. The compartment lights shall be integrated into the roll-up door tracks with the light actuation with the door opening. The compartment lights shall have adjustable halogen light bulbs that can adjust over 12 inches travel. The lights shall have a polycarbonate lens to eliminate breakage from impact and eliminate heat build up.

